


NO.	Bushing	L
1	DT10N1250	215
2	DT10N1250 DT20N1250	265
3	DT20N1250 DT30N1250	340
4	DT30N1250	440
5	DT33/250/990	480
6	DT33/250/1260	495
7	DT33/250/1320	530



with protection relay
without protection relay

* عملیات رزوه زنی بعد از جوشکاری فلانش به نوله و به طور همزمان انجام شود.
Semifinished (part 1): Forging
Uncertain tolerances according to DIN ISO 2768-m

Uncertain tolerances according to DIN ISO 2768-m							
1	1	6	Flat washer				
		-		ND 0J 06 009			
-	1	5	Fastening cap		St.37		
		-	DIN 1691(DIN EN 1561)				
1	1	4	Oil level sight glass				
		-		TUN 900101			
1	1	3	Socket				
		-		ND 0B 03 018			
1	1	2	Pipe		St.33	ø48.3x3.25xL - (1,1/2")	
		-	DIN 2440				
1	1	1	Flange		St.37-2	ø65*ø44*30	
		-					
Qt.	Item No. Index	Description		Identity No.	Material Standard	Dimension	Mass. Kg
Index	Mod.No.	Date	Modifications		Signature	Title: Filling Pipe (R 1,1/2") (for oil sight glass with protection relay or just oil sight glass installing)	
						Ordered by:	
Tolerance:		Group:	Applied by: Z.Azjodi		Drawing Identification: I T R I - - R 1 1		
Scale: --			Check by: A Karamzadeh		Drawing No.: N D 0 B 0 3 - 0 1 7 -		
		شرکت ترانسفورماتور توزیع زنجان ZANJAN DISTRIBUTION TRANSFORMER CO.		Approved by: F.Joulaei		Date: 1399/06/16	Page Count No.: 1
						Page No.: 1-	



شرکت ترانسفورماتور توزیع زنجان
ZANGAN DISTRIBUTION TRANSFORMER CO.